

BRANZ-CM-1005 - Rev1

#### Certificate No:

Date of Issue: 20 February 2019 **Revision Date:** 20 February 2022

#### CERTIFICATE HOLDER



#### Laminex New Zealand

1 O'Rorke Road Penrose Auckland

Tel: 0800 303 606

Fax: 0800 303 707

Web: www.laminex.co.nz

#### CERTIFICATION BODY



1222 Moonshine Rd. RD1. Porirua 5381 Private Bag 50 908 Porirua 5240. New Zealand

04 237 1170 Tel: Email: assuranceservices@branz.co.nz Web: branz.nz



Chelydra Percy Chief Executive Officer **BRANZ** Limited

# **JAS-ANZ**

vww.ias-anz.org/register

## **PRODUCT CERTIFICATE** THIS IS TO CERTIFY STRANDSARKING<sup>®</sup> ROOF SARKING

#### DESCRIPTION OF PRODUCT

Strandsarking® is an engineered wood-based panel material for use as roof sarking under asphalt shingles, profiled metal roofing and other similar types of roofing materials. All panels are ink marked with the New Zealand Timber Preservation Council registration number and treatment type, Strandsarking and a five digit traceability code.

#### **USE OF PRODUCT**

Strandsarking<sup>®</sup> is for use as roof sarking on buildings within the following scope:

- in accordance with the scope limitations of NZS 3604; and,
- with timber roof framing designed in accordance with NZS 3604, or timber roof members subject to specific design; and,
- in NZS 3604 Wind Zones up to and including Extra High; and,
- in areas with a maximum snow loading of 1 kPa, and;
- with a minimum roof pitch of 9°; and,
- with roof trusses or framing at maximum of 900 mm centres with roofing materials up to 50 kg/m<sup>2</sup>; and,
- with roof trusses or framing at maximum of 600 mm centres with roofing materials up to 150 kg/m<sup>2</sup>.

#### COMPLIES WITH THE FOLLOWING PROVISIONS OF THE NEW ZEALAND BUILDING CODE (NZBC)

Clause B1 STRUCTURE: Performance B1.3.1, B1.3.2, B1.3.3 (a), (b), (c), (g), (h), and (q), and B1.3.4. Clause B2 DURABILITY: Performance B2.3.1 (b) 15 years and B2.3.2 (a). Clause F2 HAZARDOUS BUILDING MATERIALS: Performance F2.3.1

The Certificate Holder must maintain compliance with the conditions set out in Regulation 15 of the Building (Product Certification) Regulations 2008



This Certificate is issued by BRANZ Limited, an independent certification body accredited by the product certification body appointed by the Chief Executive of the Ministry of Business, Innovation and Employment (MBIE) under the Building Act 2004. MBIE does not in any way warrant, quarantee or represent that the building method or product the subject of this certificate conforms with the New Zealand Building Code, nor accept any liability arising out of the use of the building method or product. MBIE disclaims, to the extent permitted by law, all liability [including negligence] for claims of losses, expenses, damages and costs arising as a result of the use of the building method(s) or products(s) referred to in this certificate.

It is advised to check that this Product Certificate is currently valid and not withdrawn, suspended or superseded by a later issue, by referring to the MBIE website, www.mbie.govt.nz

This certificate may only be reproduced in its entirety



BRANZ-CM-1005 - Rev1
20 February 2019
20 February 2022

#### CERTIFICATE HOLDER



#### Laminex New Zealand

1 O'Rorke Road
Penrose
Auckland

- Tel: 0800 303 606
- Fax: 0800 303 707
- Web: www.laminex.co.nz

#### CERTIFICATION BODY



#### **BRANZ Limited**

1222 Moonshine Rd. RD1, Porirua 5381 Private Bag 50 908 Porirua 5240. New Zealand

04 237 1170 Tel: Email: assuranceservices@branz.co.nz Web: branz.nz



Chelydra Percy Chief Executive Officer **BRANZ** Limited

#### SUBJECT TO THE FOLLOWING CONDITIONS AND LIMITATIONS

- The maximum exposure period for Strandsarking<sup>®</sup> before being clad with the roofing system is 8 weeks.
- The moisture content of the Strandsarking<sup>®</sup> must be controlled in accordance with the provisions of NZBC Acceptable Solutions E2/AS1 and E3/AS1, NZS 3604, and the Technical Literature.
- A roof underlay must be used under the roofing material.
- Roof space ventilation must be provided under Strandsarking<sup>®</sup> installations.
- Strandsarking<sup>®</sup> must not be used as roof bracing (diaphragm roofs).
- The manufacturer does not intend Strandsarking<sup>®</sup> to be used at elevations above sea level greater than 500 m.

#### **REFERENCE DOCUMENTS**

This Product Certificate must be read in conjunction with:

- BRANZ Appraisal No 891 (2015) Strandsarking® Roof Sarking.
- Technical Literature: Strandsarking® Technical Manual, Edition 4, 07/19.

## **APPENDIX A - PRODUCT TECHNICAL DATA**

PRODUCT SPECIFICATION A1:

> Strandsarking® is manufactured from strands of radiata pine. The wood strands are treated with a water-based organic preservative and insecticide and contain a mineral wax-based water repellent. They are bonded with a pMDI resin.

> Strandsarking® has a nominal thickness of 16.3 mm and comes as square edge panel. It has a textured surface to provide a macro-texture for a more slip resistant top surface than is available with smooth sanded panel products. The panels have an average density of 685 kg/m<sup>3</sup> and average moisture content of 10% at manufacture.

> For the purposes of calculating the building performance index of the building envelope the R-value of Strandsarking<sup>®</sup> 16.3 mm panels should be taken as 0.14 m<sup>2</sup> K/W. This has been determined through testing by BRANZ.

The product is available as 3600 mm x 800 mm panels with a nominal mass per panel of 32 kg and nominal mass per square metre of 11 kg/m<sup>2</sup>.

Fixings for Strandsarking<sup>®</sup> are as follows:

- 65 mm x 2.8 mm diameter ring shanked hot dipped galvanised flat head nails; or,
- 65 mm x 2.8 mm diameter ring shanked stainless steel flat head nails; or,
- 50 mm x 10 gauge (4.8 mm) stainless steel screws.


#### INSTALLATION REQUIREMENTS A2:

**JAS-ANZ** 

Installation must be carried out in accordance with the following:

- BRANZ Appraisal No 891 (2015) Strandsarking<sup>®</sup> Roof Sarking.
- Technical Literature: Strandsarking® Technical Manual, Edition 4, 07/19.

The Certificate Holder must maintain compliance with the conditions set out in Regulation 15 of the Building (Product Certification) Regulations 2008



It is advised to check that this Product Certificate is currently valid and not withdrawn, suspended or superseded by a later issue, by referring to the MBIE website, www.mbie.govt.nz

This certificate may only be reproduced in its entirety vww.ias-anz.org/register



BRANZ-CM-1005 - Rev1

20 February 2019

#### Certificate No: Date of Issue:

**Revision Date:** 20 February 2022

#### CERTIFICATE HOLDER



#### Laminex New Zealand

1 O'Rorke Road Penrose Auckland

Tel: 0800 303 606

Fax: 0800 303 707

#### Web: www.laminex.co.nz

#### CERTIFICATION BODY



1222 Moonshine Rd. RD1, Porirua 5381 Private Bag 50 908 Porirua 5240. New Zealand

04 237 1170 Tel: Email: assuranceservices@branz.co.nz Web: branz.nz



Chelydra Percy Chief Executive Officer **BRANZ** Limited



### **APPENDIX B - OTHER RELEVANT TECHNICAL DATA**

#### B1: GENERAL

B2:

Strandsarking® panels must be laid with the long edge perpendicular to the trusses or rafters in a staggered pattern (brickbond). The ends of each panel must be supported by a truss or rafter or by solid blocking.

Each panel of Strandsarking<sup>®</sup> should span at least two spans (i.e. be continuous over three trusses or rafters). Where Strandsarking<sup>®</sup> is over a single span (i.e. supported by only two trusses or rafters) solid blocking must be provided to support all edges. Profiled metal roofing must be fixed through Strandsarking® to support framing.

It has been determined by BRANZ that roof material including Strandsarking® not exceeding a mass of 25 kg/m<sup>2</sup> is to be considered as Light Roof for design in accordance with NZS 3604. Roof material including Strandsarking® with a mass of greater than 25 kg/m<sup>2</sup> is defined as Heavy Roof.

#### PREVENTION OF FIRE OCCURING

Separation or protection must be provided to Strandsarking® from heat sources such as fire places, heating appliances, flues and chimneys. Part 7 of NZBC Acceptable Solutions C/AS1 - C/AS6 and NZBC Verification Method C/VM1 provide methods for separation and protection of combustible materials from heat sources.

#### B3: INSTALLATION

Strandsarking® fixings at panel ends and at intermediate supports must be at 150 mm maximum centres, except that in NZS 3604 Wind Zones Very High and Extra High, the fixings to intermediate supports must be at 100 mm centres maximum.

A 3 mm gap must be left between each Strandsarking<sup>®</sup> panel in order to allow for normal expansion of the panels in service.

A 5 mm clearance must be left between Strandsarking® panels and any other elements protruding through the roof.

Roofing material suppliers must be consulted in order to ascertain the specific ventilation requirements for their particular system. Refer to the Technical Literature.

The Certificate Holder must maintain compliance with the conditions set out in Regulation 15 of the Building (Product Certification) Regulations 2008.

vww.ias-anz.org/register

This Certificate is issued by BRANZ Limited, an independent certification body accredited by the product certification body appointed by the Chief Executive of the Ministry of Business, Innovation and Employment (MBIE) under the Building Act 2004. MBIE does not in any way warrant, guarantee or represent that the building method or product the subject of this certificate conforms with the New Zealand Building Code, nor accept any liability arising out of the use of the building method or product. MBIE disclaims, to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the building method(s) or products(s) referred to in this certificate.

It is advised to check that this Product Certificate is currently valid and not withdrawn, suspended or superseded by a later issue, by referring to the MBIE website, www.mbie.govt.nz

This certificate may only be reproduced in its entirety

Pg 3 of 4



 Certificate No:
 BRANZ-CM-1005 - Rev1

 Date of Issue:
 20 February 2019

 Revision Date:
 20 February 2022

#### **CERTIFICATE HOLDER**



#### Laminex New Zealand

1 O'Rorke Road Penrose Auckland

Tel: 0800 303 606

Fax: 0800 303 707

#### Web: <u>www.laminex.co.nz</u>

#### CERTIFICATION BODY



BRANZ Limited

1222 Moonshine Rd, RD1, Porirua 5381 Private Bag 50 908 Porirua 5240, New Zealand

Tel: 04 237 1170 Email: <u>assuranceservices@branz.co.nz</u> Web: <u>branz.nz</u>

Chiliple lein

Chief Executive Officer BRANZ Limited

## **APPENDIX C - BASIS OF CODEMARK CERTIFICATION**

The following tests have been carried out on Strandsarking®:

- Testing in accordance with the requirements of AS/NZS 1860.1 and BRANZ criteria to demonstrate structural and durability performance.
- The change in the physical properties of Strandsarking<sup>®</sup>, including modulus of rupture, modulus of elasticity, internal bond strength, thickness swell and surface water absorption after natural weathering have been determined by BRANZ.
- Formaldehyde emission levels have been determined by testing to AS/NZS 4266.16. The results of these tests have been reviewed by BRANZ and found to be satisfactory.
- BRANZ testing and monitoring of wood-based panel products through BRANZ Appraisals since 1977.

The referenced Technical Literature has been examined by BRANZ and found to be satisfactory.

The quality of supply to the market is the responsibility of Laminex New Zealand

Building designers are responsible for the design of the building, and for the incorporation of the Strandsarking<sup>®</sup> into their design in accordance with the instructions of Laminex New Zealand.


Quality of installation is the responsibility of the installer in accordance with the instructions of Laminex New Zealand.

#### SOURCES OF INFORMATION

- AS/NZS 1860.1: 2002 Particleboard flooring Part 1: Specifications
- AS/NZS 4266.16:2004 Reconstituted wood based panels Methods of test. Method 16: Formaldehyde emission Desiccator method.
- BRANZ Appraisal No. 891 (2015) Strandsarking® Roof Sarking.
- NZS 3604: 2011 Timber-framed buildings.
- Acceptable Solutions and Verification Methods for New Zealand Building Code Protection from Fire Clauses C1-C6, Ministry of Business, Innovation and Employment, First Edition April 2002 [Amendment 4, 1 January 2017]
- Acceptable Solutions and Verification Methods for New Zealand Building Code External Moisture Clause E2, Ministry of Business, Innovation and Employment, Third Edition July 2005 (Amendment 8, 30 November 2018).
- Acceptable Solutions and Verification Methods for New Zealand Building Code Internal Moisture Clause E3, Ministry of Business, Innovation and Employment, Second Edition February 1998 (Amendment 6, 01 January 2017).
- Ministry of Business, Innovation and Employment Record of Amendments for Compliance Documents and Handbooks.
- The Building Regulations 1992.

**JAS-ANZ** 

The Certificate Holder must maintain compliance with the conditions set out in Regulation 15 of the Building (Product Certification) Regulations 2008.



It is advised to check that this Product Certificate is currently valid and not withdrawn, suspended or superseded by a later issue, by referring to the MBIE website, www.mbie.govt.nz

www.jas-anz.org/register This certificate may only be reproduced in its entirety.